



RAD -Radiation Assay Device

By Alexandra Moody Honor Biology Class Middleton High School






Radiation Exposure



Radiation Dosimeters




- Flight Samples
 - Particle Track High LET
 - •OSL Low LET

- Ground Control
 - Particle Track High LET
 - •OSL Low LET




Mean Radiation Dosage



Shuttle Small Payloads Project Office Symposium 99

Film Procedure





Pre-flight Control






Space Flown Sample



Post-flight Control




SEM Passive Experiment Housing With Film





Results of Shuttle Flight



The space-flown sample returned fogged



The unexpectedly high fogging was due to:

- Radiation alone ?
- Long storage time ?
- Dry nitrogen atmosphere ?
- □Heat exposure?

OR

■Some combination of factors?



Verifying the Film Results


Dr. Don Fry of the MUSC Department of Radiology set up a test to expose film samples to measured x-ray radiation doses.

328 mR 1186 mR 4650 mR





The luggage X-ray machine at Charleston International Airport was also used to test the effects of radiation.




Note: ROYAL GOLD 1000 Film is very sensitive to environmental radiation; expose and process it promptly. Request visual inspection at airport x-ray inspection stations. Some x-ray equipment may fog this film.

(from Kodak film technical information)



Film Results



Pre

Post

Airport STS-85

328

1186

4650

Shuttle Small Payloads Project Office Sympsium 99



MUSC Department of Pathology Image Analysis Core Facility




Film scanned.



Density measured.





Conclusions

The data supports the evidence that the film was affected by radiation.



Applications for Space Travel

- High-speed photographic films need special shielding.
- Choose lower sensitivity films
- Test to verify the choice





CAN DO Project CAN



For further information,

www.musc.edu/cando

